


Wiring Diagram

EL420, EL520, MP420, MP520



A	B	C	D	E	F	H
Door UK	Handle	Cylinder	Bolt in	Bolt out	Potential free control	Monitoring cable sabotage loop Potential free loop is closed when connection cable is connected to lockcase.

Fire alarm overrides timer's open control, if loop 16-18 is closed.
Handle egress allowed

G	Fire alarm	Dip 4	Fire alarm
N.C loop 17-18 closed	No Fire alarm	0	OFF
N.O loop 17-18 open	Fire alarm	1	ON