

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0809-CPR-1159

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Electromechanically operated locks

used on fire and/or smoke compartmentation doors and described on page 2

placed on the market under the name or trade mark of

Abloy Oy

Wahlforssinkatu 20
FI-80101 Joensuu

and produced in the manufacturing plant

Abloy Oy

Wahlforssinkatu 20
FI-80101 Joensuu.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 14846:2008

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on November 26, 2015 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The validity of the certificate may be confirmed at the web address www.sertifikaattihaku.fi.

Espoo May 21, 2024



Katja Vahtikari
Manager, Construction Certification



Heli Välimäki
Senior Expert

Product family: Solid door single point motorized solenoid Din		
Product	Performance / Classification	
Abloy EL560L EL564L BL560	Self-closing ability - closing force - return force on latch bolt	Grade 5 (up to 200 kg, max. closing force 25 N)
	Durability of self-closing action - durability - number of test cycles	Grade S (200 000 test cycles)
	Resistance to fire E (integrity) and I (insulation)	Grade F (120 min)

Product family: Narrow stile door single point motorized solenoid Din		
Product	Performance / Classification	
Abloy BL460 EL460L	Self-closing ability - closing force - return force on latch bolt	Grade 5 (up to 200 kg, max. closing force 25 N)
	Durability of self-closing action - durability - number of test cycles	Grade S (200 000 test cycles)
	Resistance to fire E (integrity) and I (insulation)	Grade D (60 min)